



(E) 4" MAIN LINE (TYP)
 EXISTING RISER UP FROM MECHANICAL ROOM
 BELOW - DEMO

SCOPE OF WORK NOTES:
 1. ENTIRE FIRE SPRINKLER SYSTEM SHALL BE REMOVED COMPLETELY INCLUDING ALL DEVICES, EQUIPMENT, SPRINKLER HEADS BACK TO FLOOR INSIDE LOCATED IN MECH ROOM. ASSUME NOTHING CAN BE REUSED OR SALVAGED.

1 SECOND FLOOR FIRE PROTECTION SPRINKLER DEMO PLAN
 TOTAL SQFT FOOTPRINT = 29,222
 SCALE: 1/8" = 1'-0"

HEAD COUNT

○ SEMI REC QR	= 222
○ SSU	= 28
◄ DRY SSU	= 0

4067 e. grant rd ■ suite 200
 tucson, az 85712
 phone : (520) 325-4122
 fax : (520) 325-4123

ADAMS
 ASSOCIATES, INC.

PRELIMINARY -
 NOT FOR CONSTRUCTION

NELLIS AFB
 REPAIR FIRE PROTECTION SYSTEM
 BLDG. 200
 KENLY DR.
 LAS VEGAS, NV

**SECOND FLOOR
 FIRE PROTECTION SYSTEM
 SPRINKLER DEMO PLAN**

Revisions _____

Date: **03-10-10**
 Job No.: **10039**
 Drawn By: **L.R.**
 Designed By: **S.A.**
 Checked By: **S.A.**

Sheet No.: **FP1.2**